

Evidence of Performance

Resistance to wind load

Watertightness

Air permeability

Test Report 10-001301-PB01-A01-02-en-02



Client **BAUPLAST PAZARLAMA PLASTIK**
SAN. İÇ VE DIŞ TİC. A.Ş
Bağlar mah. Osmanpaşa cad. No:21 KAT:2

GÜNEŞLİ-BAĞCILAR/İSTANBUL
Turkey

Basis

EN 14351-1 : 2006-03

Test standards:

EN 1026 : 2000-06

EN 1027 : 2000-06

EN 12211 : 2000-06

EN 12046-1 : 2003-11


EN 14609 : 2004-03

Test Report 102 42739/1e dated 30. July 2010

Test Report 10-001301-PB01-A01-02-en-01 dated 9 November 2010

Corresponds to the national standard (DIN EN)

Representation



Product	Single leaf tilt and turn window
BAU	BAU 5000
Overall dimensions (w x h)	700 mm x 1,300 mm
Frame material	PVC-U/white
Special features	Reinforcements mitred and mounted without cutback. Locking points under maximum hold. Glazing rebate horizontal at bottom additional sealed with pourable sealant.

Resistance to wind load – EN 12210



Class C4

Watertightness – EN 12208



Class 8A

Air permeability – EN 12207



Class 4

Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1:2006-03. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1:2006-03 shall be observed.

Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

Contents

The report contains a total of 9 pages

ift Rosenheim
3 March 2011


Jörg Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department

Building Components
ift Rosenheim GmbH



Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl


Robert Kolacny, Dipl.-Ing. (FH)
Operating Product Officer
Building Components

Theodor
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

z: 83026 Rosenheim
Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkante PUZ-Stelle: BAY 18

DAP-PL-0808 99
DAP-ZE-2288 00
TGA-ZM-16-93-00
TGA-ZM-16-93-60