

# Evidence of Performance

Resistance to wind load

Watertightness

Air permeability

Test Report 10-001301-PB03-A01-02-en-02



Client **BAUPLAST PAZARLAMA PLASTİK**  
**SAN. İÇ VE DIŞ TİC. A.Ş**  
Bağlar mah. Osmanpaşa cad. No:21 KAT:2

**GÜNEŞLİ-BAĞCILAR/İSTANBUL**  
Turkey

## Basis

EN 14351-1 : 2006-03

Test standards:

EN 1026 : 2000-06

EN 1027 : 2000-06

EN 12211 : 2000-06

EN 12046-1 : 2003-11


EN 14609 : 2004-03

Test Report 102 42739/3e dated  
30 July 2010

Test Report 10-001301-PB03-  
A01-02-en-01 dated  
9 November 2010

Corresponds to the national  
standard (DIN EN)

## Representation



Product	Single leaf tilt and turn window
System	BAU 7100
Overall dimensions (w x h)	800 mm x 1,600 mm
Frame material	PVC-U/white
Special features	Reinforcements mitred and mounted without cutback.

Resistance to wind load – EN 12210



**Class E2100**

Watertightness – EN 12208



**Class 9A**

Air permeability – EN 12207



**Class 4**

## Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1:2006-03. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1:2006-03 shall be observed.

## Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

## Notes on publication

The **ift**-Guidance Sheet "Conditions and Guidance for the Use of **ift** Test Documents" applies.

The cover sheet can be used as an abstract.

## Contents

The report contains a total of  
10 pages

ift Rosenheim  
3 March 2011

  
Jörg Peter Lass, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Components

  
Robert Kolacny, Dipl.-Ing. (FH)  
Operating Product Officer  
Building Components



ift Rosenheim GmbH  
Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Theodor-Giethl-Str. 7 - 9  
D-83026 Rosenheim  
Tel.: +49 (0)8031/261-0  
Fax: +49 (0)8031/261-290  
www.ift-rosenheim.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14763  
Sparkasse Rosenheim  
Kto. 3822  
BLZ 711 500 00

Notified Body Nr.: 0757  
Anerkante PUZ-Stelle: BAY 18  
 DAP-PL-0808 99  
DAP-ZE-2288 00  
TGA-ZM-16-93-00  
TGA-ZM-16-93-60