

Evidence of Performance

Resistance to wind load
Watertightness
Air permeability
Operating forces

Test Report 102 42709/1e U



Client **Bauplast Pazarlama
San.Tic.A.S.
Istoc Taptancilar Carsisi 25.Ada No.: 115-117**

**BAGCILAR Mahmut Bey Istanbul
Turkey**

Basis

EN 14351-1 : 2006-03

Test standards:

EN 1026 : 2000-06

EN 1027 : 2000-06

EN 12211 : 2000-06

EN 12046-1 : 2003-11


EN 14609 : 2004-03

Test report 102 41670/1e dated
8. January 2010

Corresponds to the national
standard (DIN EN)

Product	Single leaf tilt and turn casement door
System	BAU 9100
Overall dimensions (w x H)	950 mm x 2,000 mm
Frame material	PVC-U/white
Special features	Bracings mitred and mounted without cutback

Representation



Resistance to wind load – EN 12210



Class C5 / B5

Watertightness – EN 12208



Class E900

Air permeability – EN 12207



Class 3

Operating forces – EN 13115



Class 1

Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1:2006-03. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1:2006-03 shall be observed.

Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

Contents

The report contains a total of 11 pages

ift Rosenheim
2. March 2010


Jörg Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
ift Centre Windows & Facades


Robert Kolacny, Dipl.-Ing. (FH)
Test engineer
ift Centre Windows & Facades



ift Rosenheim GmbH

Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Giethl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkante PUZ-Stelle: BAY 18
 DAP-PL-0808 99
DAP-ZE-2288 00
TGA-ZM-16-93-00
TGA-ZM-16-93-60